

North American Hazardous Location Approval

The following information applies when operating the product in hazardous locations.

In-Chassis Modules

MVI46, MVI56, MVI71 and MVI94 Series

CL I Div 2 GPs A, B, C, D
Temp Code T5
0° C ≤ Ta ≤ 60° C

WARNING - EXPLOSION HAZARD - SUBSTITUTION OF ANY COMPONENTS MAY IMPAIR SUITABILITY FOR CLASS I, DIVISION 2.

WARNING - EXPLOSION HAZARD - WHEN IN HAZARDOUS LOCATIONS, TURN OFF POWER BEFORE REPLACING OR REWIRING MODULES.

WARNING - EXPLOSION HAZARD - DO NOT DISCONNECT EQUIPMENT UNLESS POWER HAS BEEN SWITCHED OFF OR THE AREA IS KNOWN TO BE NON-HAZARDOUS.

SUITABLE FOR USE IN CLASS I, DIVISION 2 GROUPS A, B, C AND D HAZARDOUS LOCATIONS OR NON-HAZARDOUS LOCATIONS.

FOR MVI46 MODELS:

FOR USE ONLY WITH ALLEN BRADLEY POWER SUPPLY CAT. NO. 1747-P1, -P2, -P3 OR -P4 AND ALLEN BRADLEY ROCK 1746-A4, -A7, -A10 OR -A13.

FOR MVI56 MODELS:

FOR USE ONLY WITH ALLEN BRADLEY POWER SUPPLY CAT. NO. 1756 FOLLOWED BY -PA72/B OR -PB72/B OR 1756-PB72/C.

FOR MVI71 MODELS:

FOR USE ONLY WITH ALLEN BRADLEY POWER SUPPLY CAT. NO. 1771-P4S, -P6S, -P4S1 OR -P6S1 AND RACK 1771-A1B.

FOR MVI94 MODELS:

FOR USE ONLY WITH ALLEN BRADLEY POWER SUPPLY CAT. NO. CABPS1 OR A LISTED CLASS 2 POWER SUPPLY.

AVERTISSEMENT - RISQUE D'EXPLOSION - SUBSTITUTION DE TOUTE COMPOSANTS PEUT RENDRE LA CONFORMITÉ À CLASS I, DIVISION 2.

AVERTISSEMENT - RISQUE D'EXPLOSION - QUAND DANS DES ENDROITS DANGEREUX, COUPEZ L'ALIMENTATION AVANT DE REMPLACER OU MODULES RECÂBLAGE.

AVERTISSEMENT - RISQUE D'EXPLOSION - NE PAS COUPER EQUIPMENT QUE L'ALIMENTATION EST COUPÉE OU QUE LA ZONE EST CONNUE POUR ÊTRE NON DANGEREUX.

ADAPTÉ POUR UNE UTILISATION EN CLASSE I, DIVISION 2 GROUPES A, B, C ET D DES ENDROITS DANGEREUX OU NON DANGEREUX.

POUR MVI46 MODÈLES:

POUR UTILISATION UNIQUEMENT AVEC ALLEN BRADLEY ALIMENTATION CAT. NON. 1747-P1, -P2, -P3 OU -P4 ET ALLEN BRADLEY ROCK 1746-A4, -A7, -A10 OU -A13.

POUR MVI56 MODÈLES:

POUR UTILISATION UNIQUEMENT AVEC ALLEN BRADLEY ALIMENTATION CAT. NON. 1756 SUIVIE PAR -PA72 / B OU -PB72 / B OU 1756-PB72 / C.

POUR MVI71 MODÈLES:

POUR UTILISATION UNIQUEMENT AVEC ALLEN BRADLEY ALIMENTATION CAT. NON. 1771-P4S, -P6S, -P4S1 OU -P6S1 ET RACK 1771-A1B.

POUR MVI94 MODÈLES:

POUR UTILISATION UNIQUEMENT AVEC ALLEN BRADLEY ALIMENTATION CAT. NON. CABPS1 OU UN RÉPERTOIRÉE CLASSE 2 ALIMENTATION.

MVI56E and MVI69 Series

CL I Div 2 GPs A, B, C, D
Temp Code T5
0° C ≤ Ta ≤ 60° C

Except for MVI56E-****XT
-25° C ≤ Ta ≤ 70° C

Except for MVI56E-61850C
-25° C ≤ Ta ≤ 50° C SERIES B CHASSIS
-25° C ≤ Ta ≤ 60° C SERIES C CHASSIS

THIS EQUIPMENT IS SUITABLE FOR USE IN CLASS I, DIVISION 2, GROUPS A, B, C AND D OR NON-HAZARDOUS LOCATIONS ONLY.

WARNING - EXPLOSION HAZARD - DO NOT DISCONNECT EQUIPMENT WHILE THE CIRCUIT IS LIVE OR UNLESS THE AREA IS KNOWN TO BE FREE OF IGNITABLE CONCENTRATIONS.

WARNING - EXPLOSION HAZARD - SUBSTITUTION OF ANY COMPONENT MAY IMPAIR SUITABILITY FOR CLASS I, DIVISION 2.

THIS EQUIPMENT MUST BE INSTALLED WITHIN A SUITABLE ENCLOSURE WITH A TOOL REMOVABLE COVER OR DOOR.

ADAPTÉ POUR UNE UTILISATION EN CLASSE EMPLACEMENTS NON DANGEREUX SEULEMENT I, DIVISION 2, GROUPES A, B, C ET D LIEUX DANGEREUX OU.

AVERTISSEMENT - RISQUE D'EXPLOSION - NE PAS COUPER EQUIPEMENT LORSQUE LE CIRCUIT EST EN DIRECT OU MOINS QUE LA ZONE EST SAVOIR ÊTRE LIBRE DE CONCENTRATION INFLAMMABLES.

AVERTISSEMENT - RISQUE D'EXPLOSION - SUBSTITUTION DE TOUT COMPOSANT PEUT NUIRE CONFORMITÉ À CLASS I, DIVISION 2.

CET ÉQUIPEMENT DOIT ÊTRE INSTALLÉ DANS UNE ENCEINTE APPROPRIÉE AVEC UN COUVERCLE OU UNE PORTE AMOVIBLE POUR OUTIL.

MVI69E and MVI69L Series

CL I Div 2 GPs A, B, C, D
Temp Code T6
0° C ≤ Ta ≤ 60° C

THIS EQUIPMENT IS SUITABLE FOR USE IN CLASS I, DIVISION 2, GROUPS A, B, C, D OR NON-HAZARDOUS LOCATIONS ONLY.

WARNING - EXPLOSION HAZARD - SUBSTITUTION OF ANY COMPONENTS MAY IMPAIR SUITABILITY FOR CLASS I, DIVISION 2.

WARNING - EXPLOSION HAZARD - DO NOT DISCONNECT EQUIPMENT UNLESS POWER HAS BEEN SWITCHED OFF OR THE AREA IS KNOWN TO BE NON-HAZARDOUS.