

CL I Div 2 GPs A, B, C, D
Temp Code 4A
-25° C ≤ Ta ≤ 70° C

THIS EQUIPMENT IS SUITABLE FOR USE IN CLASS I, DIVISION 2, GROUPS A, B, C, D OR NON-HAZARDOUS LOCATIONS ONLY.

WARNING - EXPLOSION HAZARD - SUBSTITUTION OF ANY COMPONENTS MAY IMPAIR SUITABILITY FOR CLASS I, DIVISION 2.

WARNING - EXPLOSION HAZARD - DO NOT DISCONNECT EQUIPMENT UNLESS POWER HAS BEEN SWITCHED OFF OR THE AREA IS KNOWN TO BE NON-HAZARDOUS.

CET APPAREIL EST VALABLE POUR UTILISATION EN CLASSE I, DIVISION 2, GROUPES A, B, C, D OU NON DANGEREUX.

AVERTISSEMENT - RISQUE D'EXPLOSION - SUBSTITUTION DE TOUTE COMPOSANTS PEUT RENDRE LA CONFORMITÉ À CLASS I, DIVISION 2.

AVERTISSEMENT - RISQUE D'EXPLOSION - NE PAS COUPER EQUIPMENT QUE L'ALIMENTATION EST COUPÉE OU QUE LA ZONE EST CONNUE POUR ÊTRE NON DANGEREUX.

5xxx Series

CL I Div 2 GPs A, B, C, D
Temp Code T4
-20° C ≤ Ta ≤ 50° C

POWER, INPUT AND OUTPUT (I/O) WIRING MUST BE IN ACCORDANCE WITH CLASS I, DIVISION 2 WIRING METHODS ARTICLE 501-4(B) OF THE NATIONAL ELECTRICAL CODE, NFPA 70 FOR INSTALLATIONS IN THE U.S., OR AS SPECIFIED IN SECTION 18-1J2 OF THE CANADIAN ELECTRICAL CODE FOR INSTALLATIONS WITHIN CANADA AND IN ACCORDANCE WITH THE AUTHORITY HAVING JURISDICTION.

WARNING - EXPLOSION HAZARD - SUBSTITUTION OF COMPONENTS MAY IMPAIR SUITABILITY FOR CLASS I, DIVISION 2.

WARNING - EXPLOSION HAZARD - WHEN IN HAZARDOUS LOCATIONS, TURN OFF POWER BEFORE REPLACING WIRING MODULES.

WARNING - EXPLOSION HAZARD - DO NOT DISCONNECT EQUIPMENT UNLESS POWER HAS BEEN SWITCHED OFF OR THE AREA IS KNOWN TO BE NONHAZARDOUS.

ALIMENTATION, ENTREE ET SORTIE (I / O) CÂBLAGE DOIT ÊTRE CONFORME AUX CLASS I, DIVISION 2 MODÈS DE RACCORDEMENT ARTICLE 501-4 (B) DU CODE ÉLECTRIQUE NATIONAL, NFPA 70 POUR LES INSTALLATIONS DES ÉTATS-UNIS, OU COMME SPÉCIFIÉ À L'ARTICLE 18 -1J2 DU CODE CANADIEN DE L'ÉLECTRICITÉ POUR INSTALLATIONS AU CANADA ET CONFORMÉMENT À LA JURIDICTION AUTORITÉ.

AVERTISSEMENT - RISQUE D'EXPLOSION - SUBSTITUTION DE COMPOSANTS PEUT RENDRE LA CONFORMITÉ À CLASS I, DIVISION 2.

AVERTISSEMENT - RISQUE D'EXPLOSION - QUAND DANS DES ENDROITS DANGEREUX, COUPEZ L'ALIMENTATION AVANT DE REMPLACER MODULES DE RACCORDEMENT.

AVERTISSEMENT - RISQUE D'EXPLOSION - NE PAS COUPER EQUIPMENT QUE L'ALIMENTATION EST COUPÉE OU QUE LA ZONE EST CONNUE COMME NON DANGEREUSE.

Wireless Gateways

ICX35-HWC-A

© 2021 ProSoft Technology. All Rights Reserved.
949-0100 Rev 1.5.2

CL I Div 2 GPs A, B, C, D
Temp Code T5
-40° C ≤ Ta ≤ 70° C

THIS EQUIPMENT IS AN OPEN-TYPE DEVICE AND IS MEANT TO BE INSTALLED IN AN ENCLOSURE, SUITABLE FOR THE ENVIRONMENT SUCH THAT THE EQUIPMENT IS ONLY ACCESSIBLE WITH THE USE OF A TOOL.

SUITABLE FOR USE IN CLASS I, DIVISION 2, GROUPS A, B, C AND D HAZARDOUS LOCATIONS, OR NONHAZARDOUS LOCATIONS ONLY.

WARNING - EXPLOSION HAZARD - DO NOT DISCONNECT EQUIPMENT WHILE THE CIRCUIT IS LIVE OR UNLESS THE AREA IS KNOWN TO BE FREE OF IGNITABLE CONCENTRATIONS.

WARNING - EXPLOSION HAZARD - SUBSTITUTION OF ANY COMPONENT MAY IMPAIR SUITABILITY FOR CLASS I, DIVISION 2.

CET APPAREIL EST OUVERT UN DISPOSITIF DE TYPE ET EST DESTINÉ À ÊTRE INSTALLÉ DANS UNE ENCEINTE ADAPTE POUR L'ENVIRONNEMENT TELS QUE L'EQUIPEMENT EST ACCESSIBLE SEULEMENT AVEC L'UTILISATION D'UN OUTIL.

ADAPTÉ POUR UNE UTILISATION EN CLASSE EMPLACEMENTS NON DANGEREUX SEULEMENT I, DIVISION 2, GROUPES A, B, C ET D LIEUX DANGEREUX OU.

AVERTISSEMENT - RISQUE D'EXPLOSION - NE PAS COUPER EQUIPEMENT LORSQUE LE CIRCUIT EST EN DIRECT OU SI LA ZONE EST CONNUE POUR ÊTRE DÉPOURVUE DE CONCENTRATIONS INFLAMMABLES.

AVERTISSEMENT - RISQUE D'EXPLOSION - SUBSTITUTION DE TOUT COMPOSANT PEUT NUIRE CONFORMITÉ À CLASS I, DIVISION 2.

RLX2-IHNF-W and RLX2-IHNF-WC

CL I Div 2 GPs A, B, C, D
Temp Code T4
-40° C ≤ Ta ≤ 70° C

THE EQUIPMENT SHALL BE PROPERLY GROUNDED WITH THE EXTERNAL GROUND SCREW PROVIDED CONNECTED TO BUILDING GROUND AS WELL AS THE ANTENNA COAXIAL SCREEN OF THE CONNECTOR SHALL BE GROUNDED.

THE COMMON OR EARTH SIDE OF THE CIRCUIT IS CONNECTED TO THE SCREEN OF THE COAXIAL CABLE AND TO ALL ACCESSIBLE PARTS AND CIRCUITS.

SHALL BE INSTALLED IN RESTRICTED ACCESS LOCATION ONLY.

SUITABLE FOR USE IN CLASS I, DIVISION 2, GROUPS A, B, C AND D HAZARDOUS LOCATIONS, OR NONHAZARDOUS LOCATIONS ONLY.

WARNING - EXPLOSION HAZARD - DO NOT DISCONNECT EQUIPMENT WHILE THE CIRCUIT IS LIVE OR UNLESS THE AREA IS KNOWN TO BE FREE OF IGNITABLE CONCENTRATIONS.

WARNING - EXPLOSION HAZARD - SUBSTITUTION OF COMPONENT MAY IMPAIR SUITABILITY FOR CLASS I, DIVISION 2.

FOR MODEL RLX2-IHNF-W-CC: UNIT MUST BE WIRED WITH PHOENIX CONTACT M12 CABLE ASSEMBLIES, MODEL SERIES SAC-HZ-XX-XX-XX/XX-XXX/XXXXXXXXXX, THAT ARE SUITABLE FOR USE IN CLASS I, DIVISION 2, GROUPS A, B, C AND D HAZARDOUS LOCATIONS.